

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-0245:110 Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: Ruskin Manufacturing, 3900 Dr. Greaves Road, Grandview, MO 06303 Contact Person:
Robert Van Becelaere (816) 761-7476

DESIGN: Model FSD60 leakage rated damper. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, leakage rating and UL label.

APPROVAL: Listed as a Class 1-A leakage-rated damper, (Exception: Dampers under 12" wide are Leakage Class II). Dampers shall be used with UL Listed operators/actuators. For all FSD-60 dampers greater than 12.5 square feet in size, it is intended that only UL listed Model 331-3060 fire damper operator be used.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 14, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager